

NEW RESIDENTIAL WATER SERVICE REGULATIONS

ALL NEW WATER SERVICE LINES SHALL BE AT LEAST 1 IN. TYPE K COPPER. DEPTH OF LINES AFTER FINAL GRADE SHALL BE 48 IN. MIN. TO 60 IN. MAX. ALL FITTINGS SHALL BE COMPRESSION TYPE. BACKFILL SHALL BE #8 OR #9 STONE.

APPROVED WATER SERVICE PARTS:

BALL VALVE CORPORATION STOP – FORD FB1000–xx–Q–NL, MUELLER 300 BALL TYPE WITH 110 COMPRESSION CONNECTION

BALL VALVE CURB STOP – FORD B44–xxx–Q–NL, MUELLER 300 B25209

QUICK JOINT COUPLING – FORD C44–xx–Q–NL, MUELLER 3 PART UNION H–15403

SERVICE BOX (2 1/2") – BINGHAM & TAYLOR 93–E (33"–52"), BINGHAM & TAYLOR 94–E (40"–60"), TYLER 6500 SERIES, 95E

NEW WATER SERVICES WILL REQUIRE A LINE HYDROSTATIC TEST OF 200 PSI FOR A DURATION OF 5 MINUTES. ALL FITTINGS AND COPPER LINES WILL BE EXPOSED FOR INSPECTION. THE SITE WILL BE AT FINAL GRADE OR STAKED FOR FINAL GRADE TO DETERMINE DEPTH OF COVER. AT NO TIME WILL AN APPROVAL BE GIVEN WITHOUT FOLLOWING THIS PROCEDURE. REQUESTS FOR INSPECTION SHALL BE MADE ONE WORKING DAY PRIOR TO TIME OF INSPECTION. CONTACT THE UTILITY OFFICE AT 330–335–2700 OR THE METER SERVICE DEPARTMENT AT 330–335–2831 TO SCHEDULE AN INSPECTION.

CURB BOXES SHALL REST ON A CONCRETE BLOCK OR BRICK AND NO PART OF THE BOX SHALL TOUCH THE VALVE OR COPPER WATER SERVICE LINE. RISERS WILL NOT BE ALLOWED. THE LOCATION OF NEW CURB BOX VALVES WILL NOT BE IN THE SIDEWALK OR CLOSER THAN ONE FOOT FROM THE SIDEWALK OR BACK OF CURB. ALL EFFORTS SHOULD BE MADE TO KEEP THE SERVICE OUT OF THE DRIVE APRON WHEN POSSIBLE.

ANY EXISTING CURB STOPS OR MAINLINE VALVES ARE TO BE OPERATED BY AUTHORIZED CITY PERSONNEL ONLY.

NEW WATER METER REGULATIONS

THE METER LOCATION SHALL BE SUCH THAT THE METER IS READILY AVAILABLE FOR MAINTENANCE, REPLACEMENT, AND READING. ALL NEW SERVICES ARE REQUIRED TO HAVE A REMOTE READER WHICH REQUIRES A WIRE FROM THE METER TO THE REMOTE READER LOCATION. IT IS RECOMMENDED THE REMOTE READER BE LOCATED NEAR THE ELECTRIC METER; HOWEVER THE WATER DEPARTMENT MAY SUGGEST ANOTHER LOCATION. THIS WIRE CAN BE INSTALLED PRIOR TO FINISHING TO AVOID DRILLING THROUGH FINISHED WALLS BY CALLING THE UTILITY OFFICE AT 330–335–2700 OR THE METER SERVICE DEPARTMENT AT 330–335–2831 ONE WORKING DAY PRIOR TO INSPECTION.

METER SETTINGS AND BACKFLOW DEVICES WILL BE DETERMINED BY THE UTILITY OFFICE OR METER SERVICE DEPARTMENT.

OCCUPANCY PRIOR TO FINAL INSPECTION AND APPROVAL OF THE WATER SERVICE AND WATER METER INSTALLATION IS PROHIBITED.

CONSTRUCTION WATER

METERED CONSTRUCTION WATER IS AVAILABLE BY REQUEST BY CONTACTING THE UTILITY OFFICE.

UNMETERED CONSTRUCTION WATER IS AVAILABLE FOR A PERIOD NOT TO EXCEED SIX (6) MONTHS. THIS WATER IS TO BE USED STRICTLY FOR CONSTRUCTION PURPOSES. ANY USE OF UNMETERED WATER OTHER THAN FOR CONSTRUCTION (I.E. LAWN WATERING) SHALL CAUSE THE SERVICE TO BE DISCONNECTED UNTIL PAYMENT FOR ESTIMATED WATER USE IS RECEIVED AND A WATER METER INSTALLED.

FINAL ACCEPTANCE

THE FINAL ACCEPTANCE OF THE CURB STOP WILL BE AFTER FINAL GRADING, SEEDING, AND SIDEWALK AND THE WATER DEPARTMENT IS SATISFIED WITH THE PRESSURE TEST, BURY DEPTH, OFFSET FROM THE CURB AND SIDEWALK, AND A WATER KEY CAN EASILY GET ON THE VALVE WITHIN A VERTICAL CURB BOX. ANY DAMAGE TO CURB BOXES AND STOPS PRIOR TO FINAL ACCEPTANCE IS THE RESPONSIBILITY OF THE CONTRACTOR/PROPERTY OWNER. NO PERMANENT SERVICE WILL BE ESTABLISHED OR METER SET UNLESS THE CURB STOP IS ACCEPTED, ACCESSIBLE, OPERATIONAL, AND ALL FEES PERTAINING TO THE WATER SERVICE ARE PAID. SEE PLANS FOR ADDITIONAL INFORMATION (IF APPLICABLE).

ANY QUESTIONS ARE TO BE DIRECTED TO THE UTILITY OFFICE AT 330–335–2700 OR METER SERVICE DEPARTMENT AT 330–335–2831.

SEE CITY OF WADSWORTH DETAIL WAT–03 FOR ADDITIONAL INFORMATION.



NEW RESIDENTIAL WATER SERVICE AND
METER REGULATIONS

WAT–07
3/24/20